

Site Radon Inspection Report

Date : 08/03/2016

Mr. Jeff Hayes
TOP NOTCH HOME INSPECTION
16415 Wayne Drive
Oregon City, OR 97045-

Client: Elementary School code# 95C
Test Location: 38875 Northwest 1st Avenue
Scio, OR 97374-

Individual Canister Results

Canister ID# : 2469263 Test Start : 07/29/2016 @ 11:34
Canister Type : Charcoal Canister 3 inch Test Stop : 08/01/2016 @ 18:17
Location : EPC11 Received: 08/03/2016 @ 11:37
Radon Level : 0.3 pCi/L Analyzed: 08/04/2016 @ 10:08
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2469266 Test Start : 07/29/2016 @ 11:25
Canister Type : Charcoal Canister 3 inch Test Stop : 08/01/2016 @ 17:27
Location : EPB7 Received: 08/03/2016 @ 11:37
Radon Level : 0.5 pCi/L Analyzed: 08/04/2016 @ 10:29
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2469267 Test Start : 07/29/2016 @ 11:37
Canister Type : Charcoal Canister 3 inch Test Stop : 08/01/2016 @ 18:19
Location : EM1 Received: 08/03/2016 @ 11:37
Radon Level : 0.1 pCi/L Analyzed: 08/04/2016 @ 10:29
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2469823 Test Start : 07/29/2016 @ 11:37
Canister Type : Charcoal Canister 3 inch Test Stop : 08/01/2016 @ 18:19
Location : EM1 Received: 08/03/2016 @ 11:37
Radon Level : 0.2 pCi/L Analyzed: 08/04/2016 @ 10:29

Average of Side by Side Canisters 0.2 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2469825 Test Start : 07/29/2016 @ 12:18
Canister Type : Charcoal Canister 3 inch Test Stop : 08/01/2016 @ 18:24
Location : E Caf South Received: 08/03/2016 @ 11:37
Radon Level : 0.2 pCi/L Analyzed: 08/04/2016 @ 10:08
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2469835 Test Start : 07/29/2016 @ 12:25
Canister Type : Charcoal Canister 3 inch Test Stop : 08/01/2016 @ 18:28
Location : E Gym West Received: 08/03/2016 @ 11:37
Radon Level : 0.8 pCi/L Analyzed: 08/04/2016 @ 10:46



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 08/03/2016

Mr. Jeff Hayes
TOP NOTCH HOME INSPECTION
16415 Wayne Drive
Oregon City, OR 97045-

Client: Elementary School code# 95C
Test Location: 38875 Northwest 1st Avenue
Scio, OR 97374-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	2469836	Test Start :	07/29/2016 @ 11:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	08/01/2016 @ 18:20
Location :	EM2	Received:	08/03/2016 @ 11:37
Radon Level :	0.1 pCi/L	Analyzed:	08/04/2016 @ 10:45
Error for Measurement is: \pm	0.8 pCi/L		

Canister ID# :	2469842	Test Start :	07/29/2016 @ 11:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	08/01/2016 @ 18:15
Location :	EPC9	Received:	08/03/2016 @ 11:37
Radon Level :	0.2 pCi/L	Analyzed:	08/04/2016 @ 10:29
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	2469862	Test Start :	07/29/2016 @ 11:27
Canister Type :	Charcoal Canister 3 inch	Test Stop :	08/01/2016 @ 17:30
Location :	EPB6	Received:	08/03/2016 @ 11:37
Radon Level :	0.4 pCi/L	Analyzed:	08/04/2016 @ 10:29
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	2469864	Test Start :	07/29/2016 @ 12:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	08/01/2016 @ 18:24
Location :	E Caf North	Received:	08/03/2016 @ 11:37
Radon Level :	0.4 pCi/L	Analyzed:	08/04/2016 @ 11:23
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	2469868	Test Start :	07/29/2016 @ 12:25
Canister Type :	Charcoal Canister 3 inch	Test Stop :	08/01/2016 @ 18:28
Location :	E Gym East	Received:	08/03/2016 @ 11:37
Radon Level :	0.5 pCi/L	Analyzed:	08/04/2016 @ 10:45
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	2469873	Test Start :	07/29/2016 @ 12:25
Canister Type :	Charcoal Canister 3 inch	Test Stop :	08/01/2016 @ 18:28
Location :	BLANK E Gym	Received:	08/03/2016 @ 11:37
Radon Level :	0.1 pCi/L	Analyzed:	08/04/2016 @ 10:45
Error for Measurement is: \pm	0.2 pCi/L		



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 08/03/2016

Mr. Jeff Hayes
TOP NOTCH HOME INSPECTION
16415 Wayne Drive
Oregon City, OR 97045-

Client: Elementary School code# 95C
Test Location: 38875 Northwest 1st Avenue
Scio, OR 97374-

Individual Canister Results

Canister ID# : 2469881
Canister Type : Charcoal Canister 3 inch
Location : EPC10
Radon Level : 0.4 pCi/L
Error for Measurement is: \pm 0.2 pCi/L
Test Start : 07/29/2016 @ 11:32
Test Stop : 08/01/2016 @ 18:16
Received: 08/03/2016 @ 11:37
Analyzed: 08/04/2016 @ 10:08

Canister ID# : 2469911
Canister Type : Charcoal Canister 3 inch
Location : E Gym East
Radon Level : 0.5 pCi/L
Error for Measurement is: \pm 0.2 pCi/L
Test Start : 07/29/2016 @ 12:25
Test Stop : 08/01/2016 @ 18:28
Received: 08/03/2016 @ 11:37
Analyzed: 08/03/2016 @ 16:51

Canister ID# : 2469914
Canister Type : Charcoal Canister 3 inch
Location : EPB5
Radon Level : 0.5 pCi/L
Error for Measurement is: \pm 0.2 pCi/L
Test Start : 07/29/2016 @ 11:27
Test Stop : 08/01/2016 @ 17:29
Received: 08/03/2016 @ 11:37
Analyzed: 08/04/2016 @ 10:08

Canister ID# : 2469923
Canister Type : Charcoal Canister 3 inch
Location : EPB8
Radon Level : 0.9 pCi/L
Error for Measurement is: \pm 0.2 pCi/L
Test Start : 07/29/2016 @ 11:29
Test Stop : 08/01/2016 @ 17:32
Received: 08/03/2016 @ 11:37
Analyzed: 08/04/2016 @ 10:08

Canister ID# : 2470834
Canister Type : Charcoal Canister 3 inch
Location : EPC12
Radon Level : 0.3 pCi/L
Error for Measurement is: \pm 0.2 pCi/L
Test Start : 07/29/2016 @ 11:34
Test Stop : 08/01/2016 @ 18:17
Received: 08/03/2016 @ 11:37
Analyzed: 08/04/2016 @ 10:46

Canister ID# : 2470845
Canister Type : Charcoal Canister 3 inch
Location : E Caf Kitchen
Radon Level : 0.4 pCi/L
Error for Measurement is: \pm 0.2 pCi/L
Test Start : 07/29/2016 @ 12:18
Test Stop : 08/01/2016 @ 18:23
Received: 08/03/2016 @ 11:37
Analyzed: 08/04/2016 @ 11:23



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 08/03/2016

Mr. Jeff Hayes
TOP NOTCH HOME INSPECTION
16415 Wayne Drive
Oregon City, OR 97045-

Client: Elementary School code# 95C
Test Location: 38875 Northwest 1st Avenue
Scio, OR 97374-

Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or it's consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 08/17/2016

Mr. Jeff Hayes
TOP NOTCH HOME INSPECTION
16415 Wayne Drive
Oregon City, OR 97045-

Client: Elementary School
Test Location: 38875 Northwest 1st Avenue
Scio, OR 97374-

Individual Canister Results

Canister ID# : 2452147 Test Start : 08/12/2016 @ 10:22
Canister Type : Charcoal Canister 3 inch Test Stop : 08/15/2016 @ 10:01
Location : ESL Received: 08/17/2016 @ 10:01
Radon Level : 0.5 pCi/L Analyzed: 08/18/2016 @ 16:27
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2452785 Test Start : 08/12/2016 @ 10:24
Canister Type : Charcoal Canister 3 inch Test Stop : 08/15/2016 @ 10:02
Location : ESSW Received: 08/17/2016 @ 10:01
Radon Level : 0.9 pCi/L Analyzed: 08/18/2016 @ 16:27
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2452791 Test Start : 08/11/2016 @ 14:39
Canister Type : Charcoal Canister 3 inch Test Stop : 08/15/2016 @ 10:07
Location : ES Caf 1 Received: 08/17/2016 @ 10:01
Radon Level : 0.5 pCi/L Analyzed: 08/18/2016 @ 16:08
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2466078 Test Start : 08/12/2016 @ 10:18
Canister Type : Charcoal Canister 3 inch Test Stop : 08/15/2016 @ 10:05
Location : ES CO Received: 08/17/2016 @ 10:01
Radon Level : 1.1 pCi/L Analyzed: 08/18/2016 @ 16:48
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2466080 Test Start : 08/12/2016 @ 10:17
Canister Type : Charcoal Canister 3 inch Test Stop : 08/15/2016 @ 09:59
Location : ES P Received: 08/17/2016 @ 10:01
Radon Level : 2.6 pCi/L Analyzed: 08/18/2016 @ 16:48
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2467650 Test Start : 08/11/2016 @ 14:41
Canister Type : Charcoal Canister 3 inch Test Stop : 08/15/2016 @ 10:08
Location : ES Caf 3 Received: 08/17/2016 @ 10:01
Radon Level : 0.2 pCi/L Analyzed: 08/18/2016 @ 15:50
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George
Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 08/17/2016

Mr. Jeff Hayes
TOP NOTCH HOME INSPECTION
16415 Wayne Drive
Oregon City, OR 97045-

Client: Elementary School
Test Location: 38875 Northwest 1st Avenue
Scio, OR 97374-

Individual Canister Results

Canister ID# :	2490321	Test Start :	08/12/2016 @ 10:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	08/15/2016 @ 10:03
Location :	ESB	Received:	08/17/2016 @ 10:01
Radon Level :	1.0 pCi/L	Analyzed:	08/18/2016 @ 16:27
Error for Measurement is: ±	0.3 pCi/L		

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201