

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 6081204
Report Date: 08/24/2016
ORELAP #: OR100028
Purchase Order: Elementary
Project Name: 201
Project No: Scio School Dist.

Cover Letter

Jeff Hayes
Top Notch Home Inspection, LLC
16415 Wayne Dr.
OREGON CITY, OR 97045

Dear Jeff Hayes,

Enclosed please find Pixis Labs analytical report for samples received as order number 6081204 on 08/12/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed

Richard Reid

Project Manager

Sample Results

Sample: ESBB1 #43		Collected: 08/11/16 14:30		Temp: 25 C		Matrix: Drinking Water			
Lab ID: 118264		Received: 08/12/16 07:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0183	1.3	mg/L	0.0010	1	29206-134		08/18/16 18:42	
Lead	0.0084	0.02	mg/L	0.0002	1	29206-134		08/18/16 18:42	
Sample: ESBB2 #44		Collected: 08/11/16 14:30		Temp: 25 C		Matrix: Drinking Water			
Lab ID: 118265		Received: 08/12/16 07:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0291	1.3	mg/L	0.0010	1	29206-135		08/18/16 18:44	
Lead	0.0110	0.02	mg/L	0.0002	1	29206-135		08/18/16 18:44	
Sample: EB Caf DF #45		Collected: 08/11/16 14:33		Temp: 25 C		Matrix: Drinking Water			
Lab ID: 118266		Received: 08/12/16 07:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0409	1.3	mg/L	0.0010	1	29206-136		08/18/16 18:46	
Lead	0.0002	0.02	mg/L	0.0002	1	29206-136		08/18/16 18:46	

Abbreviations

MRL Method Reporting Limit

ND None Detected at or above the MRL

Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter

