

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 6082317R3

Report Date: 08/30/2016

ORELAP #: OR100028

Project Name: 201

Project No: Scio School District

Cover Letter

Jeff Hayes

Top Notch Home Inspection, LLC

16415 Wayne Dr.

OREGON CITY, OR 97045

Dear Jeff Hayes,

Enclosed please find Pixis Labs analytical report for samples received as order number 6082317 on 08/23/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

This report has been amended to update the lead action limit to 0.020 mg/L.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed

Richard Reid

Project Manager

Sample Results

Sample: HSVGB 1 L #1		Collected: 08/22/16 11:50	Temp: 17 C	Matrix: Drinking Water					
Lab ID: 119108		Received: 08/23/16 10:29	Evidence of Cooling:N						
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.121	0.02	mg/L	0.0002	1	29255-180		08/24/16 21:29	
Sample: HSVGB 1 R #2		Collected: 08/22/16 11:50	Temp: 17 C	Matrix: Drinking Water					
Lab ID: 119109		Received: 08/23/16 10:29	Evidence of Cooling:N						
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0260	0.02	mg/L	0.0002	1	29255-181		08/24/16 21:31	
Sample: HS8.1 Top #3		Collected: 08/22/16 11:55	Temp: 17 C	Matrix: Drinking Water					
Lab ID: 119110		Received: 08/23/16 10:29	Evidence of Cooling:N						
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.408	0.02	mg/L	0.0002	1	29255-182		08/24/16 21:34	
Sample: HS8.1 Bottom #4		Collected: 08/22/16 12:00	Temp: 17 C	Matrix: Drinking Water					
Lab ID: 119111		Received: 08/23/16 10:29	Evidence of Cooling:N						
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0378	0.02	mg/L	0.0002	1	29255-183		08/24/16 21:36	
Sample: ST Ice #5		Collected: 08/22/16 12:07	Temp: 17 C	Matrix: Drinking Water					
Lab ID: 119112		Received: 08/23/16 10:29	Evidence of Cooling:N						
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.679	1.3	mg/L	0.0010	1	29255-184		08/24/16 21:38	
Sample: ST Ice Mop #6		Collected: 08/22/16 12:09	Temp: 17 C	Matrix: Drinking Water					
Lab ID: 119113		Received: 08/23/16 10:29	Evidence of Cooling:N						
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0006	0.02	mg/L	0.0002	1	29255-185		08/24/16 21:40	
Sample: HS DF #2		Collected: 08/22/16 12:26	Temp: 17 C	Matrix: Drinking Water					
Lab ID: 119114		Received: 08/23/16 10:29	Evidence of Cooling:N						
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0368	0.02	mg/L	0.0002	1	29255-186		08/24/16 21:42	

Abbreviations

MRL Method Reporting Limit

ND None Detected at or above the MRL

Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical

Limit results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter



Top Notch Home Inspection, LLC

PIXIS Labs

Accurate. Reliable. On Time.

Keller

h

Chain of Custody Record

12423 NE Whitaker Way
 Portland, OR 97230
 Phone: (503) 254-1794 Fax: (503) 254-1452
 www.pixislabs.com

Please inform us if you know or suspect that your sample contains hazardous chemicals.

Some or all of this analyses may be subcontracted to an ORELAP accredited lab.

Company: <u>Top Notch Home Inspection LLC</u> Contact: <u>Jeff Hayes</u> Address: <u>16415 Wayne Dr Oregon City Or 97045</u> Email: <u>jeff@tnhinspection.com</u> Phone: <u>(503) 657-4257</u> Billing (if different): _____ Fax: (____) _____				Analysis Requested						Purchase Order Number: _____ Project Number: <u>201</u> Project Name: <u>Scio School District</u> <input type="checkbox"/> Report Instructions: <input checked="" type="checkbox"/> State Compliance Format <input checked="" type="checkbox"/> Email Final Results <input type="checkbox"/> Fax Final Results <input type="checkbox"/> Cash/Check/CC/Net 30 Other: _____		
Field ID	Date/Time Collected							Matrix	Comments	#Cnr		
<u>HSVGB 1 L</u>	<u>#1 8-22 1150</u>	<u>X</u>	<u>Lead</u>	<u>Copper</u>					<u>Lead and Copper</u>			
<u>HSVGB 1 R</u>	<u>#2 8-22 1150</u>	<u>X</u>							<u>Lead and Copper</u>			
<u>HS 8.1 Top</u>	<u>#3 8-22 1155</u>	<u>X</u>							<u>Lead and Copper</u>			
<u>HS 8.1 Bottom</u>	<u>#4 8-22 1200</u>	<u>X</u>							<u>Lead and Copper</u>			
<u>ST ICE</u>	<u>#5 8-22 1207</u>			<u>X</u>					<u>Lead and Copper</u>			
<u>ST Ice map</u>	<u>#6 8-22 1209</u>	<u>X</u>							<u>Lead and Copper</u>			
<u>HS DF #2</u>	<u>#7 8-22 1226</u>	<u>X</u>							<u>Lead and Copper</u>			
									<u>Lead and Copper</u>			
									<u>Lead and Copper</u>			
									<u>Lead and Copper</u>			
									<u>Lead and Copper</u>			

Collected By: <u>[Signature]</u> <input checked="" type="checkbox"/> Standard <input type="checkbox"/> Priority (1.5 Times Standard) <input type="checkbox"/> Rush (2 Times Standard) <input type="checkbox"/> Emergency (3 Times Standard) Ask About Availability	Date: <u>8-23-16</u> Time: <u>1029</u>	Received By: <u>[Signature]</u>	Date: <u>8/23/16</u> Time: <u>1029</u>	Lab Use Only: Client Alias: <u>Top Notch</u> Order Number: <u>6082317</u> <input type="checkbox"/> Proper Container <input type="checkbox"/> Sample Condition <input type="checkbox"/> Temperature 4± 2°C <u>17°C</u> <input type="checkbox"/> Shipped Via: _____ Evidence of cooling: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
---	--	---------------------------------	--	---