

# PIXIS Labs

Accurate. Reliable. On Time.

## Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

**Job Number:** 6081205  
**Report Date:** 08/24/2016  
**ORELAP #:** OR100028  
**Purchase Order:** Middle School  
**Project Name:** 201  
**Project No:** Scio School Dist.

### Cover Letter

Jeff Hayes  
Top Notch Home Inspection, LLC  
16415 Wayne Dr.  
OREGON CITY, OR 97045

Dear Jeff Hayes,

Enclosed please find Pixis Labs analytical report for samples received as order number 6081205 on 08/12/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed

Richard Reid

Project Manager

### Sample Results

<b>Sample:</b> MS BLS 1 #28		Collected: 08/11/16 14:05		Temp: 25 C		Matrix: Drinking Water			
Lab ID: 118267		Received: 08/12/16 07:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0445	1.3	mg/L	0.0010	1	29190-155		08/17/16 21:41	
Lead	0.0058	0.02	mg/L	0.0002	1	29190-155		08/17/16 21:41	
<b>Sample:</b> MS BLS 2 #29		Collected: 08/11/16 14:05		Temp: 25 C		Matrix: Drinking Water			
Lab ID: 118268		Received: 08/12/16 07:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0389	1.3	mg/L	0.0010	1	29190-156		08/17/16 21:43	
Lead	0.0024	0.02	mg/L	0.0002	1	29190-156		08/17/16 21:43	
<b>Sample:</b> MS BLS 3 #30		Collected: 08/11/16 14:05		Temp: 25 C		Matrix: Drinking Water			
Lab ID: 118269		Received: 08/12/16 07:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.141	1.3	mg/L	0.0010	1	29190-157		08/17/16 21:45	
Lead	0.0252	0.02	mg/L	0.0002	1	29190-157		08/17/16 21:45	
<b>Sample:</b> MS BLS 4 #31		Collected: 08/11/16 14:05		Temp: 25 C		Matrix: Drinking Water			
Lab ID: 118270		Received: 08/12/16 07:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0322	1.3	mg/L	0.0010	1	29190-158		08/17/16 21:47	
Lead	0.0018	0.02	mg/L	0.0002	1	29190-158		08/17/16 21:47	
<b>Sample:</b> MS BLS 5 #32		Collected: 08/11/16 14:05		Temp: 25 C		Matrix: Drinking Water			
Lab ID: 118271		Received: 08/12/16 07:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0510	1.3	mg/L	0.0010	1	29190-159		08/17/16 21:50	
Lead	0.0022	0.02	mg/L	0.0002	1	29190-159		08/17/16 21:50	
<b>Sample:</b> MS BLS 6 #33		Collected: 08/11/16 14:05		Temp: 25 C		Matrix: Drinking Water			
Lab ID: 118272		Received: 08/12/16 07:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0418	1.3	mg/L	0.0010	1	29190-160		08/17/16 21:52	
Lead	0.0056	0.02	mg/L	0.0002	1	29190-160		08/17/16 21:52	
<b>Sample:</b> MS BLS 7 #34		Collected: 08/11/16 14:05		Temp: 25 C		Matrix: Drinking Water			
Lab ID: 118273		Received: 08/12/16 07:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0744	1.3	mg/L	0.0010	1	29206-122		08/18/16 18:13	

Lead 0.0176 0.02 mg/L 0.0002 1 29206-122 08/18/16 18:13

**Sample:** MS BLS 8 #35 Collected: 08/11/16 14:05 Temp: 25 C Matrix: Drinking Water  
 Lab ID: 118274 Received: 08/12/16 07:30 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0548	1.3	mg/L	0.0010	1	29206-123		08/18/16 18:15	
Lead	0.0052	0.02	mg/L	0.0002	1	29206-123		08/18/16 18:15	

**Sample:** MS GLS 1 #36 Collected: 08/11/16 14:15 Temp: 25 C Matrix: Drinking Water  
 Lab ID: 118275 Received: 08/12/16 07:30 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0905	1.3	mg/L	0.0010	1	29206-124		08/18/16 18:17	
Lead	0.0248	0.02	mg/L	0.0002	1	29206-124		08/18/16 18:17	

**Sample:** MS GLS 2 #37 Collected: 08/11/16 14:15 Temp: 25 C Matrix: Drinking Water  
 Lab ID: 118276 Received: 08/12/16 07:30 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.221	1.3	mg/L	0.0010	1	29206-125		08/18/16 18:19	
Lead	0.0499	0.02	mg/L	0.0002	1	29206-125		08/18/16 18:19	

**Sample:** MS GLS 3 #38 Collected: -- Temp: 25 C Matrix: Drinking Water  
 Lab ID: 118277 Received: 08/12/16 07:30 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.126	1.3	mg/L	0.0010	1	29206-126		08/18/16 18:22	
Lead	0.0323	0.02	mg/L	0.0002	1	29206-126		08/18/16 18:22	

**Sample:** MS GLS 4 #39 Collected: -- Temp: 25 C Matrix: Drinking Water  
 Lab ID: 118278 Received: 08/12/16 07:30 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	2.98	1.3	mg/L	0.400	400	29224-7		08/19/16 12:25	
Lead	1.72	0.02	mg/L	0.0800	400	29224-7		08/19/16 12:25	

**Sample:** MS GLS 5 #40 Collected: -- Temp: 25 C Matrix: Drinking Water  
 Lab ID: 118279 Received: 08/12/16 07:30 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.643	1.3	mg/L	0.0010	1	29206-127		08/18/16 18:26	
Lead	0.241	0.02	mg/L	0.0002	1	29206-127		08/18/16 18:26	

**Sample:** MS GLCS 6 #41 Collected: -- Temp: 25 C Matrix: Drinking Water  
 Lab ID: 118280 Received: 08/12/16 07:30 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0647	1.3	mg/L	0.0010	1	29206-133		08/18/16 18:39	
Lead	0.0361	0.02	mg/L	0.0002	1	29206-133		08/18/16 18:39	

**Abbreviations**

- MRL Method Reporting Limit
- ND None Detected at or above the MRL
- Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical

results are below this federal recommended action level.

**Units of Measure:**

mg/L Milligrams Per Liter

## Chain of Custody Record

12423 NE Whitaker Way  
 Portland, OR 97230  
 Phone: (503) 254-1794 Fax: (503) 254-1452  
 www.pixislabs.com

Please inform us if you know or suspect that  
 your sample contains hazardous chemicals.

Some or all of this analyses may be  
 subcontracted to an ORELAP accredited lab.

Company: <u>Top Notch Home Inspection LLC</u> Contact: <u>Jeff Hayes</u> Address: <u>16415 Wayne Dr Oregon City Or 97045</u> Email: <u>jeff@tninspection.com</u> Phone: <u>(503) 657-4257</u> Billing (if different): _____ Fax: (____) _____				<b>Analysis Requested</b>				Purchase Order Number: <u>middle school</u> Project Number: <u>201</u> Project Name: <u>Scio School District</u> <input type="checkbox"/> Report Instructions: <input checked="" type="checkbox"/> State Compliance Format <input checked="" type="checkbox"/> Email Final Results <input type="checkbox"/> Fax Final Results <input type="checkbox"/> Cash/Check/CC/Net 30 Other: _____		
Field ID	#	Date/Time Collected	Matrix	Comments	#Cnr					
<u>MS BLS 1</u>	<u>#28</u>	<u>8-11 1405</u>		<u>LEad and Copper</u>						
<u>MS BLS 2</u>	<u>29</u>	<u>8-11 1405</u>		<u>Lead and Copper</u>						
<u>MS BLS 3</u>	<u>30</u>	<u>8-11 1405</u>		<u>Lead and Copper</u>						
<u>MS BLS 4</u>	<u>31</u>	<u>8-11 1405</u>		<u>Lead and Copper</u>						
<u>MS BLS 5</u>	<u>32</u>	<u>8-11 1405</u>		<u>Lead and Copper</u>						
<u>MS BLS 6</u>	<u>33</u>	<u>8-11 1405</u>		<u>Lead and Copper</u>						
<u>MS BLS 7</u>	<u>34</u>	<u>8-11 1405</u>		<u>Lead and Copper</u>						
<u>MS BLS 8</u>	<u>35</u>	<u>8-11 1405</u>		<u>Lead and Copper</u>						
<u>MS GLS 1</u>	<u>36</u>	<u>8-11 1415</u>		<u>Lead and Copper</u>						
<u>MS GLS 2</u>	<u>37</u>	<u>8-11 1415</u>		<u>Lead and Copper</u>						
Collected By: <u>John Lewis</u> <input checked="" type="checkbox"/> Standard <input type="checkbox"/> Priority (1.5 Times Standard) <input type="checkbox"/> Rush (2 Times Standard) <input type="checkbox"/> Emergency (3 Times Standard) Ask About Availability		Date: <u>8-12</u> Time: <u>730</u>	Received By: _____ Date: _____ Time: _____	<b>Lab Use Only:</b> Client Alias: <u>Top Notch 140</u> Order Number: <u>LE081205</u> <input checked="" type="checkbox"/> Proper Container <input checked="" type="checkbox"/> Sample Condition <u>25°C</u> <input checked="" type="checkbox"/> Temperature 4± 2°C <input checked="" type="checkbox"/> Shipped Via: <u>Client</u> Evidence of cooling: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						

SUBMISSION OF SAMPLES WITH TESTING REQUIREMENTS TO PIXIS WILL BE UNDERSTOOD TO BE AN AGREEMENT FOR SERVICES IN ACCORDANCE WITH THE CONDITIONS LISTED ON THE BACK OF THIS FORM. Please ask for a copy of conditions

