

## TEST REPORT

TO: Scio School Dist./ Atten Ken  
38875 N 1st Ave  
Scio, OR 97374

06/29/2017

SCISCH

PO#:

### Collection Information

Date: 06/20/2017  
Time: 0815  
By: Ken  
Lab #: 20170620-129  
Location: MS coach shower

### Lab Receipt Information

06/20/2017  
1554  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0028		0.001	mg/l	0.020	06/26/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

