

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

08/24/2017

SCISCH

PO#:

Collection Information

Date: 08/08/2017
Time: 1040
By: Ken
Lab #: 20170810-023
Location: 1 MS girls shower

Lab Receipt Information

08/10/2017
1039
MH

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0020		0.001	mg/l	0.020	08/22/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: Brian E. Myers

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

08/24/2017

SCISCH

PO#:

Collection Information

Date: 08/08/2017
Time: 1041
By: Ken
Lab #: 20170810-024
Location: 2 MS shower girls

Lab Receipt Information

08/10/2017
1039
MH

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0033		0.001	mg/l	0.020	08/22/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

08/24/2017

SCISCH

PO#:

Collection Information

Date: 08/08/2017
Time: 1042
By: Ken
Lab #: 20170810-025
Location: 3 MS girls shower

Lab Receipt Information

08/10/2017
1039
MH

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0018		0.001	mg/l	0.020	08/22/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: Brian E. Myers

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

08/24/2017

SCISCH

PO#:

Collection Information

Date: 08/08/2017
Time: 1042
By: Ken
Lab #: 20170810-026
Location: 4 MS girls shower

Lab Receipt Information

08/10/2017
1039
MH

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0028		0.001	mg/l	0.020	08/22/2017	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: Bette E. Myers

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

08/24/2017

SCISCH

PO#:

Collection Information

Date: 08/08/2017
Time: 1043
By: Ken
Lab #: 20170810-027
Location: 5 MS girls shower

Lab Receipt Information

08/10/2017
1039
MH

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0021		0.001	mg/l	0.020	08/22/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: Brian E. Myers

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

08/24/2017

SCISCH

PO#:

Collection Information

Date: 08/08/2017
Time: 1044
By: Ken
Lab #: 20170810-028
Location: 6 MS girls shower

Lab Receipt Information

08/10/2017
1039
MH

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0117		0.001	mg/l	0.020	08/22/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: Brian E. Myers

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

08/24/2017

SCISCH

PO#:

Collection Information

Date: 08/08/2017
Time: 1045
By: Ken
Lab #: 20170810-029
Location: 7 MS girls shower

Lab Receipt Information

08/10/2017
1039
MH

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0112		0.001	mg/l	0.020	08/22/2017	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 