

Scio School District, Lead Results, January 2019

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008

Page 1 of 1

January 2019

NOTE: The Lead Test Results are provided here in two (2) different units so you can choose which one you want to use on your information.

ND means "No Detection" at level specified. If any lead is present, it is below 1 ppb or 0.001 ppm.

Source	Date/Time Collected	Lab #	Lead, ug/liter or ppb	Lead, mg/liter or ppm
Gym Fount	1/8/19 0658 AM	20190108-080	2.4	0.0024
Gym Unisex	1/8/19 0659 AM	20190108-081	1.0	0.0010
Boys Lock Left	1/8/19 0701 AM	20190108-082	1.4	0.0014
Boys Lock Rt	1/8/19 0702 AM	20190108-083	1.6	0.0016
Kit. DW	1/8/19 0704 AM	20190108-084	6.8	0.0068
Kit #2	1/8/19 0705 AM	20190108-085	1.5	0.0015
Girls Lock Left	1/8/19 0706 AM	20190108-086	1.2	0.0012
Girls Lock Rt.	1/8/19 0707 AM	20190108-087	2.2	0.0022
Girls Lock Fount	1/8/19 0708 AM	20190108-088	3.5	0.0035
Conference	1/8/19 0711 AM	20190108-089	ND @ 1	ND @ 0.001
Conf Bath	1/8/19 0712 AM	20190108-090	ND @ 1	ND @ 0.001
8 th Girls Left	1/8/19 0715 AM	20190108-091	ND @ 1	ND @ 0.001
8 th Girls Right	1/8/19 0716 AM	20190108-092	ND @ 1	ND @ 0.001
Boy 8 th Left	1/8/19 0717 AM	20190108-093	5.1	0.0051
Boy 8 th Right	1/8/19 0718 AM	20190108-094	1.8	0.0018
Break Room	1/8/19 0719 AM	20190108-095	ND @ 1	ND @ 0.001
Sick Room	1/8/19 0720 AM	20190108-096	8.2	0.0082
SPED	1/8/19 0721 AM	20190108-097	ND @ 1	ND @ 0.001
Science	1/8/19 0724 AM	20190108-098	1.8	0.0018
8 th Foun	1/8/19 0726 AM	20190108-099	ND @ 1	ND @ 0.001
6 th Foun	1/8/19 0728 AM	20190108-100	ND @ 1	ND @ 0.001
Mrs. K	1/8/19 0729 AM	20190108-101	1.9	0.0019
Mrs. H.U.	1/8/19 0730 AM	20190108-102	15.8	0.0158
Band	1/8/19 0732 AM	20190108-103	14.1	0.0141
D.O.	1/8/19 0733 AM	20190108-104	4.7	0.0047

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0658
By: Ken Studnick
Lab #: 20190108-080
Location: gym fount

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0024		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0659
By: Ken Studnick
Lab #: 20190108-081
Location: gym unisex

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0010		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

Customer

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0701
By: Ken Studnick
Lab #: 20190108-082
Location: boys lock left

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0014		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0702
By: Ken Studnick
Lab #: 20190108-083
Location: boy lock rt

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0016		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA


MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0704
By: Ken Studnick
Lab #: 20190108-084
Location: kit DW

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0068		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0705
By: Ken Studnick
Lab #: 20190108-085
Location: kit #2

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0015		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA


MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0706
By: Ken Studnick
Lab #: 20190108-086
Location: girls lock left

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0012		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0707
By: Ken Studnick
Lab #: 20190108-087
Location: girls lock rt

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0022		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0708
By: Ken Studnick
Lab #: 20190108-088
Location: girls lock foun.

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0035		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0711
By: Ken Studnick
Lab #: 20190108-089
Location: conference

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/23/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0712
By: Ken Studnick
Lab #: 20190108-090
Location: conf bath

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/23/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0715
By: Ken Studnick
Lab #: 20190108-091
Location: 8th girls left

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	Tech
								Date Time	
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/23/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0716
By: Ken Studnick
Lab #: 20190108-092
Location: 8th girls right

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.015	01/12/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/23/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0717
By: Ken Studnick
Lab #: 20190108-093
Location: boy 8th left

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0051		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/23/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0718
By: Ken Studnick
Lab #: 20190108-094
Location: boys 8th rt

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	Tech
								Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0018		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

Customer

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/23/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0719
By: Ken Studnick
Lab #: 20190108-095
Location: break room

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	Tech
								Date Time	
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/23/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0720
By: Ken Studnick
Lab #: 20190108-096
Location: sick room

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0082		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/23/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0721
By: Ken Studnick
Lab #: 20190108-097
Location: SPED

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	Tech
								Date Time	
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/23/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0724
By: Ken Studnick
Lab #: 20190108-098
Location: Science

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	Tech
								Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0018		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/23/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0726
By: Ken Studnick
Lab #: 20190108-099
Location: 8th Foun

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0728
By: Ken Studnick
Lab #: 20190108-100
Location: 6th foun

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA


MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

Customer

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0729
By: Ken Studnick
Lab #: 20190108-101
Location: Mrs K

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0019		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0730
By: Ken Studnick
Lab #: 20190108-102
Location: Mrs. H.U.

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0158		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0732
By: Ken Studnick
Lab #: 20190108-103
Location: Band

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0141		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Scio School Dist./ Atten Ken
38875 N 1st Ave
Scio, OR 97374

01/14/2019

SCISCH

PO#:

Collection Information

Date: 01/08/2019
Time: 0733
By: Ken Studnick
Lab #: 20190108-104
Location: D.O.

Lab Receipt Information

01/08/2019
1520
MM

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0047		0.001	mg/l	0.015	01/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

Customer

Page 1 of 1