

TEST REPORT

TO: Scio School District
38875 N 1st Ave
Scio, OR 97374

01/21/2025

SCISCH

PO#:

Collection Information

Date: 01/08/2025
Time: 0657
By: Harley
Lab #: 20250108-033
Location: Pod A Rm 1 sink

Lab Receipt Information

01/08/2025
1314
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| Analyte | Method | Acc* | Results | Qual | MRL | Units | EPA Limit | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-----------|------------|------|
| | | | | | | | | Date | Time |
| Lead / Schools | SM3113 B | A | ND | | 1 | ppb | 15 | 01/17/2025 | bem |

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____

TEST REPORT

TO: Scio School District
38875 N 1st Ave
Scio, OR 97374

01/21/2025

SCISCH

PO#:

Collection Information

Date: 01/08/2025
Time: 0657
By: Harley
Lab #: 20250108-034
Location: Rm 1 fountain James

Lab Receipt Information

01/08/2025
1314
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| Analyte | Method | Acc* | Results | Qual | MRL | Units | EPA Limit | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-----------|------------|------|
| | | | | | | | | Date | Time |
| Lead / Schools | SM3113 B | A | ND | | 1 | ppb | 15 | 01/17/2025 | bem |

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Scio School District
38875 N 1st Ave
Scio, OR 97374

01/21/2025

SCISCH

PO#:

Collection Information

Date: 01/08/2025
Time: 0700
By: Harley
Lab #: 20250108-035
Location: Room 2 sink

Lab Receipt Information

01/08/2025
1314
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| Analyte | Method | Acc* | Results | Qual | MRL | Units | EPA Limit | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-----------|------------|------|
| | | | | | | | | Date | Time |
| Lead / Schools | SM3113 B | A | ND | | 1 | ppb | 15 | 01/17/2025 | bem |

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Scio School District
38875 N 1st Ave
Scio, OR 97374

01/21/2025

SCISCH

PO#:

Collection Information

Date: 01/08/2025
Time: 0700
By: Harley
Lab #: 20250108-036
Location: Room 2 fountain

Lab Receipt Information

01/08/2025
1314
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| Analyte | Method | Acc* | Results | Qual | MRL | Units | EPA Limit | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-----------|------------|------|
| | | | | | | | | Date | Time |
| Lead / Schools | SM3113 B | A | ND | | 1 | ppb | 15 | 01/17/2025 | bem |

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Scio School District
38875 N 1st Ave
Scio, OR 97374

01/21/2025
SCISCH

PO#:

Collection Information

Date: 01/08/2025
Time: 0655
By: Harley
Lab #: 20250108-037
Location: RM 3 sink treager

Lab Receipt Information

01/08/2025
1314
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| Analyte | Method | Acc* | Results | Qual | MRL | Units | EPA Limit | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-----------|------------|------|
| | | | | | | | | Date | Time |
| Lead / Schools | SM3113 B | A | ND | | 1 | ppb | 15 | 01/17/2025 | bem |

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Scio School District
38875 N 1st Ave
Scio, OR 97374

01/21/2025

SCISCH

PO#:

Collection Information

Date: 01/08/2025
Time: 0655
By: Harley
Lab #: 20250108-038
Location: RM 3 fountain

Lab Receipt Information

01/08/2025
1314
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| Analyte | Method | Acc* | Results | Qual | MRL | Units | EPA Limit | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-----------|------------|------|
| | | | | | | | | Date | Time |
| Lead / Schools | SM3113 B | A | ND | | 1 | ppb | 15 | 01/17/2025 | bem |

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater",20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes",USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Scio School District
38875 N 1st Ave
Scio, OR 97374

01/21/2025
SCISCH

PO#:

Collection Information

Date: 01/08/2025
Time: 0653
By: Harley
Lab #: 20250108-039
Location: Rm 4 sink mcalister

Lab Receipt Information

01/08/2025
1314
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| Analyte | Method | Acc* | Results | Qual | MRL | Units | EPA Limit | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-----------|------------|------|
| | | | | | | | | Date | Time |
| Lead / Schools | SM3113 B | A | ND | | 1 | ppb | 15 | 01/17/2025 | bem |

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Scio School District
38875 N 1st Ave
Scio, OR 97374

01/21/2025

SCISCH

PO#:

Collection Information

Date: 01/08/2025
Time: 0653
By: Harley
Lab #: 20250108-040
Location: Rm 4 Fountain

Lab Receipt Information

01/08/2025
1314
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| Analyte | Method | Acc* | Results | Qual | MRL | Units | EPA Limit | Analysis | |
|----------------|----------|------|---------|------|-----|-------|-----------|------------|------|
| | | | | | | | | Date | Time |
| Lead / Schools | SM3113 B | A | ND | | 1 | ppb | 15 | 01/17/2025 | bem |

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____

