

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/10/2025

SCISCH

PO#:

### Collection Information

Date: 11/18/2025

Time: 1018

By: Phil

Lab #: 20251121-088

Location: Stadium Men Bath North Sink 21030302 301 BF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/08/2025	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/10/2025

SCISCH

PO#:

### Collection Information

Date: 11/19/2025

Time: 1000

By: Phil

Lab #: 20251121-089

Location: Bates Field Drinking Fountain 21030100 777 DW

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/08/2025	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/9/2025

SCISCH

PO#:

### Collection Information

Date: 11/12/2025

Time: 1015

By: Phil

Lab #: 20251121-016

Location: New District Office Breakroom Sink *21030090-0025 F*

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	Tech
								Date Time	
Lead / Schools	SM3113 B	A	ND		1	ppb	15	11/24/2025	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/9/2025

SCISCH

PO#:

### Collection Information

Date: 11/12/2025

Time: 1020

By: Phil

Lab #: 20251121-017

Location: New District Office Bathroom sink

### Lab Receipt Information

11/21/2025

0901

SW

21930000-001 BF

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	11/24/2025	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/10/2025

SCISCH

PO#:

### Collection Information

Date: 11/19/2025

Time: 1000

By: Phil

Lab #: 20251121-091

Location: Bus Barn Sink 21030001400 KF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/08/2025	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/10/2025

SCISCH

PO#:

### Collection Information

Date: 11/19/2025

Time: 1000

By: Phil

Lab #: 20251121-093

Location: Bus Barn Bathroom Sink 21030001 401 KF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/08/2025	bem

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/10/2025

SCISCH

PO#:

### Collection Information

Date: 11/20/2025

Time: 0646

By: Phil

Lab #: 20251121-090

Location: Wilca Kitchen sink 21030500 500 KF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/08/2025	ber

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/10/2025

SCISCH

PO#:

### Collection Information

Date: 11/19/2025

Time: 0647

By: Phil

Lab #: 20251121-094

Location: Wilca Bathroom Sink 21030500 501 BF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/08/2025	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/9/2025

SCISCH

PO#:

### Collection Information

Date: 11/18/2025

Time: 1030

By: Phil

Lab #: 20251121-020

Location: Stadium Concession sink 21030302 306 KF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	11/24/2025	bem

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/9/2025

SCISCH

PO#:

### Collection Information

Date: 11/18/2025

Time: 1003

By: Phil

Lab #: 20251121-025

Location: Maintenance Mens bathroom sink 21030304 100 BF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	11/24/2025	ber

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/9/2025

SCISCH

PO#:

### Collection Information

Date: 11/18/2025

Time: 1011

By: Phil

Lab #: 20251121-024

Location: Stadium Boys Locker Rm Bathroom sink 21030302 300 BF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	11/24/2025	ber

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/9/2025  
SCISCH

PO#:

### Collection Information

Date: 11/18/2025

Time: 1025

By: Phil

Lab #: 20251121-023

Location: Stadium Girls Locker Rm Bathroom sink 21030302 303 BF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	11/24/2025	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/9/2025

SCISCH

PO#:

### Collection Information

Date: 11/18/2025

Time: 1029

By: Phil

Lab #: 20251121-022

Location: Stadium Women Bathroom sink North 21030302 304 BF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	11/24/2025	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/9/2025  
SCISCH

PO#:

### Collection Information

Date: 11/18/2025

Time: 1031

By: Phil

Lab #: 20251121-021

Location: Stadium Women Bathroom sink South 21030302 305 BF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	11/24/2025	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/09/2025

SCISCH

PO#:

### Collection Information

Date: 11/20/2025

Time: 0712

By: Phil

Lab #: 20251121-096

Location: Stadium North Outside Faucet 21030302 308 OS

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/08/2025	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/10/2025

SCISCH

PO#:

### Collection Information

Date: 11/18/2025

Time: 1004

By: Phil

Lab #: 20251121-086

Location: Maint. Warehouse Women Bath sink 21030304 101 BF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/08/2025	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/10/2025

SCISCH

PO#:

### Collection Information

Date: 11/18/2025

Time: 1017

By: Phil

Lab #: 20251121-087

Location: Stadium Men Bath South Sink 21030302 302 BF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/08/2025	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/10/2025

SCISCH

PO#:

### Collection Information

Date: 11/19/2025

Time: 1000

By: Phil

Lab #: 20251121-092

Location: Middle School Outside Drinking Fountain 21030200 700 OS

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/08/2025	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA


MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/09/2025

SCISCH

PO#:

### Collection Information

Date: 11/20/2025

Time: 0706

By: Phil

Lab #: 20251121-095

Location: Stadium South Outside Faucet 21030302 307 OS

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	2.18		1	ppb	15	12/08/2025	bem

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Scio School District  
38875 N 1st Ave  
Scio, OR 97374

12/10/2025

SCISCH

PO#:

### Collection Information

Date: 11/18/2025

Time: 0958

By: Phil

Lab #: 20251121-085

Location: AD Room Maint. Warehouse 21030304 103 SF

### Lab Receipt Information

11/21/2025

0901

SW

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory. This report shall not be reproduced except in full without permission in writing.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead / Schools	SM3113 B	A	369.		1	ppb	15	12/09/2025	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 20th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

